

Evaluation of PEV Loading Characteristics on Hydro-Québec's Distribution System Operations

Angelo Giumento
Hydro-Québec Distribution
Montréal, Québec Canada

Dr. Arindam Maitra
Dr. Will Kook
Electric Power Research Institute

About Hydro-Québec

- Largest electric utility in Canada
- One of the world's largest producer of hydropower
- 3.9 million customers across the province of Québec
- Peak load 38,000 MW – winter peaking (98% hydraulic)
- By 2015 – 4000 MW of wind power will be online



Understanding Grid Impact

- Only *distribution system* impacts
 - no generation/emissions
- Only the PHEV *loading* impacts
 - no two-way power considerations
- When are system/component *limits exceeded*?
 - penetration and charging behavior
 - sensitivity to temporal/spatial variation
- What are *likely* near-term impacts?
 - representative penetration/charging
 - penetration levels 1-5 yrs out

Distribution Impacts

- Thermal Loading
- Voltage Regulation
- Xfmr Loss of Life
- Losses
- Imbalance
- Harmonics



PEV Characteristics

- Type/range
- Market share
- Charge profile and power level
- Customer charge behavior

Total Loading on Feeder A

Distribution Feeder – A



- This feeder supplies is a highly urban circuit containing a very large population density and lots of growth. The majority of the loads represent multifamily homes or high rise condos
 - **Number of customers** – 2801, 44% (1220 customers) of which are living at high rise condos which are served out of 3-phase transformers
 - **Territory** – 88% residential, 12% commercial, 95% underground
 - **Operating voltage** – 25KV
 - **Load factor** – 48%
 - **Load density** – 209
 - **Primary circuit length** – 13.4 miles
 - **Loading** – Winter Peaking Utility. Peak occurs on 2/28/2007. The first peak occurs at 8am and the second peak occurs at 7pm.
 - **Charging Scenario** – Evening and Night charging



Distribution Feeder – B

- This feeder supplies a typical suburban neighbourhood. Mostly middle and upper middle class families travelling by car (low public transit penetration), very prone to buying a main or secondary car
 - **Number of customers** – 1132
 - **Customer type**– 97% residential, 3% commercial
 - **Operating voltage** – 25KV
 - **Load factor** – 46%
 - **Load density** – 130
 - **Primary circuit length** – 8.7 miles
 - **Loading** – Winter Peaking Utility. Peak occurs on 2/5/2007. The first peak occurs at 8am and the second peak occurs at 6pm
 - **Charging Scenario** – Evening and Night charging

Total Loading on Feeder B



EPRI PHEV Distribution System Impacts

- **Micro level analysis of PHEV load impact**


- full electrical model of specific feeders
- sequential power flow through full year
- sensitivity of PHEV spatial/temporal variation

- **Specific Utility Results**

- impacts to specific circuits
- implications to specific design/op practices


- **Generalized Collaborative Results**

- rules of thumbs based on circuit characteristics




Question to be Addressed


- What system impacts are likely to occur?
- What level of penetration necessitates feeder/asset upgrades?
- How can the new load be managed?



Impact Analysis Methodology




Developing PHEV Scenarios





PHEV Clustering

- No data to support differentiation of customer preference
- Clusters occur from penetration and system configuration




Asset Overloads - Component Deterministic Analysis

- Service transformers and underground cables are most susceptible asset to PHEV clusters/penetration
- Service transformer overload impact is minimal even at 20% penetration on specific feeder
- Charging on peak during peak hours less than 10% of transformers are critical




Transformer Loss of Life Analysis

- 167KVA rated transformer are the most common. For this circuit, the observed max and average peak hour demand for that transformer size of all the 167KVA transformers is 127% and 59% respectively
- Influence of transformer lifespan (% insulation aging per year) & hot spot temperatures on PEV loading
- Very minimal reduction to the lifespan of the transformer due to PEV loading with the 120V charging (less than 3 months over 40 years)



Stochastic analysis



Stochastic Analysis

- On 100 stochastic scenarios

KVA	# of Xfo	Penetration 2%		Penetration 4%		Penetration 8%	
		Prob (%)	Overloaded xfos	Prob (%)	Overloaded xfos	Prob (%)	Overloaded xfos
50	16	14	1	25	1	51	3
100	80	0	0	0	0	0	0
167	2	0	0	0	0	0	0
300	3	0	0	0	0	0	0

In scenarios with a relatively low penetration levels on a "normal" residential feeder, the probability of facing lots of overloads is low.

Scenarios with higher penetration levels are in preparation (over 25%)

Summary / Q&A

- Feeder impacts: Very low on both deterministic and preliminary stochastic analysis
- Asset impacts: not significant
- Clustering may cause some problems, which will be addressed on a case by case basis
- More stochastic scenarios need to be examined
- Impacts on underground feeders and the transmission networks still need to be assessed

Merci!